

Abigail Donowho

From: tim lyda <tlyda@tillamookor.gov>
Sent: Friday, January 12, 2018 10:53 AM
To: Abigail Donowho
Subject: Cypress Street Closure


Hi Abby,

There is a picture of the street with the barricades in place on the North and South ends.

The Fire Department is requiring the hammerhead with a minimum of 120' on the back leg. That will require an additional 40' on the North side of the intersection back towards the garden area of the school. An easement from the property owner will be required to extend the road way North the required 40'.

The Fire Department will be opposing closing the street. They feel they need it for emergency access.





The 20 ft access width is a minimum for use only with an *exclusive* fire department emergency access way. For roadways or public streets, these access widths must be increased. The end length of 60 ft may remain the same, however. Variations of this hammerhead are shown